
Fwd: Engineering Comments to Extraction CDP dated may 11

1 message

Tami Yellico <tyellico@broomfield.org>
To: Eileen Albrecht <ealbrecht@broomfield.org>

Fri, May 25, 2018 at 1:01 PM

for webpage - 5/25 comments to Extraction on the CDP

----- Forwarded message -----

From: **Tami Yellico** <tyellico@broomfield.org>

Date: Fri, May 25, 2018 at 12:07 PM

Subject: Re: Engineering Comments to Extraction CDP dated may 11

To: Chandler Newhall <cnewhall@extractionog.com>

Cc: Kevin Standbridge <kstandbridge@broomfield.org>, Charles Ozaki <Cozaki@broomfield.org>, Brian Cain <bcain@extractionog.com>, KATIE ALLEN <kallen@broomfield.org>, Russ Applehans <rapplehans@broomfield.org>

Chandler,

Engineering indicates it still needs the following:

- Drainage Report **signed and stamped by licensed Professional Engineer**. Should be in accordance with Section 100 and 600 of the Broomfield Standards and Specifications.
 - Per section 610.00 All ponding facilities shall be of the **detention type**. Retention Ponds will not be approved
 - All ponds should provide water quality
 - All ponds must drain completely within 72 hours.
 - Should be designed for a minor storm of 10yr and a major of 100yr
 - All reports should include the SDI spreadsheet. For more information see the following website:
<https://maperture.digitaldataservices.com/gvh/?viewer=cswdi>
- Provide a Drainage letter for the access road plans.
 - Provide historic and proposed drainage basin map
 - Provide location and sizing for crossroad pipes both existing and proposed

Thank you,
Tami

On Fri, May 25, 2018 at 9:45 AM, Chandler Newhall <cnewhall@extractionog.com> wrote:

Hello Tami,

The comments referenced in the link provided below from Jessica were addressed in the latest submittal of the CDP. Please see page 1426 through 1430 that addressed these comments, additionally the updates were throughout Section 2(B) pages 25 through 311.

Regards,

Chandler



Chandler Newhall

370 17th Street, Suite 5300

Denver, CO 80202

Direct: 720-974-7759

Cell: 303-809-4634

cnewhall@extractionog.com

From: Tami Yellico <tyellico@broomfield.org>
Sent: Thursday, May 24, 2018 4:24 PM
To: Chandler Newhall <cnewhall@extractionog.com>
Cc: Kevin Standbridge <kstandbridge@broomfield.org>; Charles Ozaki <Cozaki@broomfield.org>
Subject: Fwd: Engineering Comments to Extraction CDP dated may 11

Chander,

Please find additional comments on the CDP from Engineering that we would request Extraction to address.

Thank you,

Tami

----- Forwarded message -----

From: Jessica Upchurch <jupchurch@broomfield.org>
Date: Thu, May 24, 2018 at 4:13 PM
Subject: Engineering Comments to Extraction CDP dated may 11
To: Tami Yellico <tyellico@broomfield.org>, Russ Applehans <rapplehans@broomfield.org>

Tami,

I couldn't find the link where we needed to add our comments but wanted to get these in your hands before I left on vacation. Engineerings comments can be found [here](#). They still have some work to do on the drainage reports and these changes may result in some pretty significant changes. None of these comments are new we are just asking for them to meet Broomfield standards on detention. I will be out of the office until 6/31 but you can discuss this will Russ if you need.

Thanks,

Jessica Upchurch, PE

Civil Engineer

City and County of Broomfield

One DesCombes Dr

Broomfield, CO 80020

303-438-6238

jupchurch@broomfield.org

--

[Tami Yellico](#)

[Director of Strategic Initiatives](#)

[City & County of Broomfield](#)

[\(303\) 464-5153](#)

--

[Tami Yellico](#)
[Director of Strategic Initiatives](#)
[City & County of Broomfield](#)
[\(303\) 464-5153](#)

--

[Tami Yellico](#)
[Director of Strategic Initiatives](#)
[City & County of Broomfield](#)
[\(303\) 464-5153](#)