



Infrastructure Investment Needs With Consideration of Risk and O&M Cost

City and County of Broomfield
Progress Report

July 15, 2025

Agenda




- Objective of current analysis
- Asset management metrics
- Funding scenarios
- Water asset findings
- Sewer & stormwater asset findings
- Conclusions
- Discussion

Objective of Current Analysis

- Analysis reported to City Council in summer 2024 was an initial phase ...
 - Prioritized infrastructure renewal needs based only on age and condition.
- This 2nd analysis phase introduces risk and operating cost impact into the prioritization process ...
 - Better aligns the technique applied with asset management best practice.
- Separate analyses were conducted for water and sewer & stormwater assets ...
 - Recognizes that separate fund accounting is applied to budget expenditures.
- Focus on pipe (Water Distribution and Sewer Collection) assets

Priority Score Intended to Emulate Capital Program Decision Making

Prioritization Factors



Prior Analysis

- **Age/Condition/Performance Rating**

- Applies TERM Federal asset decay curves
- Condition & performance based on observation, if available

- **Risk Rating**

Probability of failure x *Consequence of failure* x *Duration of failure* x *Criticality factor*

- **Benefit/Cost Rating**

NPV(O&M cost of old asset - O&M cost of new asset)
Asset Replacement Value

- **Strategic Goals Rating**

Can include response to regulatory demands and climate change vulnerability

Sum of [Factor Weighting x Project Rating] = Priority Score

Asset Management Metrics

Performance Measure Definitions

Better

SGR Backlog (2025 \$): Value of assets whose age >useful lives and in the queue for replacement.

- Assets in the queue are prioritized and funded in priority order
- Assets remain in the queue until funded

Reliability: Average failure per 100 miles of pipe

- Based on age vs rate of failure asset decay curves
- For water distribution and sewer collection assets only

Better

Better

Asset condition: On a 5-to-1 scale.

- 5 = New
- 1 = Worn

% of assets at SGR: \$-weighted average portion of assets < useful lives.

Better

Performance Measures


Definition

Example

Better

SGR Backlog (2025 \$): Value of assets whose age >useful lives and in the queue for replacement.


- Assets in the queue are prioritized and funded in priority order
- Assets remain in the queue until funded



Better

Asset condition: On a 5-to-1 scale.

- 5 = New
- 1 = Worn



Performance Measures (Cont'd)

Definition

Example

Better


Reliability: Average failure per 100 miles of pipe

- Based on age vs rate of failure asset decay curves
- For water distribution and sewer collection assets only



Better

% of assets at SGR: \$-weighted average portion of assets < useful lives.



Spending Measure Definitions

Better

Annual capital spending: \$ for assets funded from the replacement queue.

- Annual spending based on budget or actuals experience, by asset class.
- All asset classes in stacked bar chart.

Annual O&M costs: Maintenance costs associated with asset condition.

- Inspection
- Preventive/proactive/scheduled maintenance
- Corrective/reactive/unscheduled maintenance

Better

Better

Annual capital + O&M costs: Sum of the above.

Cumulative capital + O&M costs: Cumulative sum of the above.

Better

Spending Measures


Definition

Example




Annual capital spending: \$ for assets funded from the replacement queue.

- Annual spending based on budget or actuals experience, by asset class.
- All asset classes in stacked bar chart.



Annual capital + O&M costs: Sum of the above.



Spending Measures (Cont'd)

Definition


Example

Better



Annual O&M costs: Maintenance costs associated with asset condition.


- Inspection
- Preventive/proactive/scheduled maintenance
- Corrective/reactive/unscheduled maintenance



Better



Cumulative capital + O&M costs: Cumulative sum of the above.



Analysis Focuses on Water and Sewer (& Stormwater) “Utilities” Assets

- “Utilities” assets include distribution and collection (linear) assets
- “Facilities” assets include water and sewage treatment and other point location assets (e.g., pumps, lift stations)

Examined Alternative Levels of Flat Annual Funding in 2025 \$

Looked for funding levels that achieve the following objectives:

- Backlog ... limit growth from current value
- Condition ... averages for Water Pump & Lift Stations and Sewer Pipe stay above 2.5 on 5-to-1 scale
- Reliability ... limit growth from current value
- O&M cost ... limit growth


Flat annual funding applied ...

Water	Sewer & Stormwater
\$6M/yr	\$9M/yr
\$5M/yr	\$6M/yr
\$3M/yr	\$5M/yr

How Flat Annual Funding Levels Were Determined


Water

Unconstrained Funding Scenario



Sewer & Stormwater


Unconstrained Funding Scenario




Bars = unconstrained needs
Red lines = funding scenarios

Utilities (Pipe Asset) Spending in 2025-2029 Capital Program

Year-of-Expenditure \$



2025 \$ Assuming 4%/Year Inflation






Bars = 2025 to 2029 Capital Program for Utilities (excludes Facilities)
Dashed Lines = High Funding Scenarios

Water Assets Findings

Water Assets – Summary of Performance Measures

Flat Annual \$ Funding Scenarios







Water Assets

Performance Measures









May 21, 2025 3:55 PM







May 21, 2025 3:57 PM





May 21, 2025 3:58 PM




Water Assets

Spending Measures




May 21, 2025 3:55 PM


Water treatment plant investment is fully funded with higher funding



O&M cost decreases with water treatment plant investment



20-yr cumulative cost = \$250M




-
-




May 21, 2025 3:57 PM



Less spending on water treatment plant investment with lower funding



Higher O&M costs as funding is reduced





Lower cumulative cost as funding is reduced






May 21, 2025 3:58 PM

Water treatment plant spending pushed after 2025 as funding is reduced



Lower cumulative cost as funding is reduced







■
■

Sewer & Stormwater Assets Findings

Sewer Assets – Summary of Performance Measures x Funding Scenario

Flat Annual \$ Funding Scenarios









Sewer & Stormwater Assets

Performance Measures








May 21, 2025 4:01 PM










May 21, 2025 4:05 PM





May 21, 2025 4:06 PM







The background features a dark, teal-tinted aerial photograph of a city with a mountain range in the distance. A large, bright yellow circular arc is superimposed over the image, framing the central text.

Sewer & Stormwater Assets

Spending Measures







May 21, 2025 4:01 PM









May 21, 2025 4:05 PM



■
■



May 21, 2025 4:06 PM




■
■

Sewer & Stormwater Assets



Cumulative Capital + O&M Costs

Cumulative Capital + O&M Costs Sewer and Stormwater



Spending by Ward


Projected Capital Spending by Ward – Water - \$6M per Year Scenario



Same scale as Sewer spending on next slide

Scale showing magnitude of Water Treatment Plant spending

Projected Capital Spending by Ward – Sewer & Stormwater - \$9M per Year Scenario



Conclusions

Conclusions

- Recommend continuation of current spending levels for renewal / replacement of existing water and sewer & stormwater assets.
 - Water = \$6M per year (2025 \$)
 - Sewer & Stormwater = \$9M per year (2025 \$)
- Funding below these levels will result in following undesirable outcomes ...
 - Increasing backlog
 - Decreasing condition
 - Decreasing reliability
 - Increasing maintenance costs in operating budget for ...
 - Preventive / scheduled / proactive inspection and maintenance
 - Corrective / unscheduled / reactive repair

Discussion

AECOM Delivering a
better world